




Fire Related Signage Requirements



- 1. The room containing the fire alarm control panel shall have signage with either a white background with red 4" lettering or a red background with white 4" lettering as seen here:



- 2. The room containing the fire pump shall have signage with either a white background with red 4" lettering or a red background with white 4" lettering as seen here:



- 3. The building's fire department connection "FDC" shall have signage permanently installed directly behind the FDC so that is easily found by responding fire crews. The signage with either a white background with red 6" lettering or a red background with white 6" lettering. If the FDC could be mistaken for the incorrect building, the address shall be added to the bottom of the signage in 4" lettering.



- 4. All non-monitored Fire Alarm Systems shall have permanent signage installed next to every pull stations. The signs shall have either a white or red background with the opposite color in 1" lettering stating:



- 5. Any Porte cochere or overhang connected to a structure that an emergency apparatus may potentially go under, is required to have clearance signage indicating the lowest point of clearance. The signage shall be rectangular with the word "Clearance" followed by the height in feet and inches



- 6. Tactile Exit Signage (Brail) Installation Requirement – locate at "Each" Exterior Marked Exit, 5 feet on center in height and to the side to which the lock mechanism is located



- 7. Fire Extinguishers whose location is not immediately seen shall have signs installed to aid in locating

